

Certification of Hygienic Conformity

APS 2 00 003 20

Inspected object/s: Atmospheric Air Filters - Filter model series "MPF/EPA/HEPA/ULPA Filter Series"
Manufacturer: Mikropor Makina Sanayi ve Ticaret A.Ş.

The Laboratory of Air Hygiene of DMT GmbH and Co. KG hereby confirms that the filters of the inspected Atmospheric Air Filters, model series "MPF/EPA/HEPA/ULPA Filter Series (further details see report APS 2 00 003 20) meet the hygienic requirements specified by the standards and regulations listed and marked below:

- German standards
 - VDI 6022, part 1:2018-01
 - VDI 3803, part 4:2012-09

For the purpose of this certification of conformity a representative HVAC component of the filter model series mentioned above was inspected in the Laboratory of Air Hygiene, DMT GmbH and Co. KG.

Inspection Result

The inspection of the above-mentioned specimen and the appraisal of the available documents have shown, that the hygienic requirements specified by the above-mentioned and marked standards and regulations are met. Requirements referred to in other regulations were not tested*).

We hereby confirm that the inspected component meets the hygienic requirements of the specified standards and regulations.

Period of validity: 01-2020 to 01-2023

Essen, 2020-01-21



Dipl.-Ing. Silke Selck

Head of Air Hygiene Testing Body



Dr. rer. nat. Dirk Renschen

Head Product Assessment Air Conditioning & Air Quality

DMT GmbH & Co. KG
Plant- and Product Safety
Product Assessment Air Conditioning and Air Quality
Laboratory for Air Hygiene
Am TÜV 1
D-45307 Essen
Germany

www.dmt-group.com

*) This inspection does not include toxicological tests or assessments of the employed materials used in the inspected component.

TÜV NORD GROUP