Certificate

Certificate-No.: DMT HI 20231004, based on DMT test report no. APS2 00 003 20
Period of Validity: 2020-01 – 2023-01
Extension of validity: 2023-01 – 2026-01

Certification of Hygienic Conformity

The Laboratory of Air Hygiene of DMT GmbH and Co. KG hereby confirms to the company

Mikropor
Oğuz Caddesi No. 5,
06935, Ankara - Türkiye

that the reinspected **Atmospheric Air Filters, model series "MPF/EPA/HEPA/ULPA Filter Series"** (further details see report APS 2 00 003 20) meet the hygienic requirements of

VDI 6022-1:2018-01 and VDI 3803-4:2012-09.

Essen, 2023-10-19

DMT
Dirk Renschen
2023.10.19 08:52:07
+02'00'

(Dr. Renschen)

Plant & Product Safety - Laboratory for Air Hygiene

DMT (Digitale Signatur)
Johannes Schamberg
2023.10.19 07:38:49
+02'00'

(Dipl.-Ing. Joh. Schamberg)

DMT GmbH & Co. KG
Am TÜV 1, 45307 Essen

TÜVNORDGROUP